



**QPS Evaluation Services Inc**  
Testing, Certification and Field Evaluation Body  
Accredited in Canada, the USA, and Internationally

File  
**LR1049**

**CERTIFICATE OF COMPLIANCE**  
(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Amphenol EEC
Address	4050 N Rockwell Street Chicago, IL 60618 USA
Project Number	LR1049-2R3
Product	Electrical Plugs and Receptacles
Model Number	EFP Series (EFP-1-22-33-444444-55-6666-7-8-9-10) EFPV Series (EFPV-1-22-33-444444-55-6666-7-8-9-10)
Ratings	600 V, 1000A Max, 106.1W Max
Markings	Class I, Div 2 Gr ABCD, T5-T6 Ex d IIC, T5-T6 Class I Zone 1, AEx d IIC, T5-T6 Ta=-55/-40°C to +40/50/65°C
Applicable Standards	CSA C22.2 No. 182.3-1987, CSA C22.2 No. 30-1986, CSA C22.2 No. 60079-0 – 2007, CSA C22.2 No. 60079-1 - 2007 UL 1977 2 <sup>nd</sup> edition, ISA/ANSI 60079-0 -2009, ISA/ANSI 60079-1-2009 UL1203 4 <sup>th</sup> edition
Factory/Manufacturing Location	1) Amphenol EEC 4050 N Rockwell Street, Chicago, IL 60618 USA 2) Draka Marine Oil And Gas, Prysmain Group 1610 Greens Road, Suite 300, Houston, TX 77032 USA 3) CCS-Connector and Cable Specialties 4325 FM2351 Rd, Bldg 2, Suite 200, Friendswood, TX 77546 USA

**Statement of Compliance:** The product(s) identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standard(s). As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: **Dave Adams, P. Eng.**  
Manager, Hazardous Locations [Ex Equipment] Department

Signature:

Date: December 12, 2018